

CERTIFICATE OF COMPLIANCE

Certificate Number 20150612-E474828
Report Reference E474828-20150611
Issue Date 2015-JUNE-12

Issued to: BIMED TEKNIK ALETLER SAN TIC A S
BEYLIKDUZU MEVKII
SS BAKIR VE PIRINC SAN
ORKIDE CD NO 15
34524 TURKEY

**This is to certify that
representative samples of**

CABLE FITTINGS FOR USE IN ZONE CLASSIFIED
HAZARDOUS LOCATIONS
See Addendum Page.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 2225, Cables and Cable-Fittings for Use in Hazardous
(Classified) Locations.
CAN/CSA-C22.2 No. 60079-0:11, Explosive atmospheres -
Part 0: Equipment — General requirements.
CAN/CSA C22.2 No. 60079-7:12, Explosive atmospheres -
Part 7: Equipment protection by increased safety “e”.
CAN/CSA-C22.2 No. 60079-31:12, Explosive atmospheres
- Part 31: Equipment dust ignition protection by enclosure
“t”.

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20150612-E474828
Report Reference E474828-20150611
Issue Date 2015-JUNE-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Cable Fittings, Series Orion, KBA followed by numerals 1 thru 5, may be followed by S, XS, XM or L, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS, for use in Class I, Zone 1, AEx e IIC; Ex e IIC Gb; Zone 21, Ex tb IIIC Db Hazardous Locations. For use only with unarmored TC-ER-HL cable. Thread sizes 1/2 to 1-1/2 in. NPT inclusive or M20 to M50 inclusive.


Cable Fittings, Series Orion, KBA followed by numerals 1 thru 10, may be followed by S, XS, XM or L, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS, for use in Class I, Zone 2, AEx e IIC; Ex e IIC Gc; Zone 22, AEx tc IIIC; Ex tc IIIC Dc Hazardous Locations. For use only with unarmored TC, TC-ER and TC-ER-HL cable. Thread sizes 1/2 to 3-1/2 in. NPT inclusive or M20 to M110 inclusive.

Cable Fittings, Series Orion Lower Temperature (Orion LT), KBA followed by numerals 1 thru 3, may be followed by X, followed by M or N, followed by LT, followed by B, BN, X, followed by C or S, may be followed by -WC or -WS, for use in Class I, Zone 1, AEx e IIC; Ex e IIC Gb; Zone 21, Ex tb IIIC Db Hazardous Locations. For use only with unarmored TC-ER-HL cable. Thread sizes 1/2 to 1 in. NPT inclusive or M20 to M32 inclusive.

Cable Fittings, Series Orion Lower Temperature (Orion LT), KBA followed by numerals 1 thru 3, may be followed by X, followed by M or N, followed by LT, followed by B, BN, X, followed by C or S, may be followed by -WC or -WS, for use in Class I, Zone 2, AEx e IIC; Ex e IIC Gc; Zone 22, AEx tc IIIC; Ex tc IIIC Dc Hazardous Locations. For use only with unarmored TC, TC-ER and TC-ER-HL cable. Thread sizes 1/2 to 1 in. NPT inclusive or M20 to M32 inclusive.

Cable Fittings, Series Taurus KBAT followed by numerals 1 thru 5, may be followed by S or L, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS, for use in Class I, Zone 1, AEx e IIC; Ex e IIC Gb; Zone 21, Ex tb IIIC Db Hazardous Locations. For use only with unarmored TC-ER-HL cable. Thread sizes 1/2 to 1-1/4 in. NPT inclusive or M20 to M40 inclusive.

Cable Fittings, Series Taurus KBAT followed by numerals 1 thru 6, may be followed by S or L, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS, for use in Class I, Zone 2, AEx e IIC; Ex e IIC Gc; Zone 22, AEx tc IIIC; Ex tc IIIC Dc Hazardous Locations. For use only with unarmored TC, TC-ER and TC-ER-HL cable. Thread sizes 1/2 to 2 in. NPT inclusive or M20 to M63 inclusive.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

